

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE



LISTING No. 7300-1615: 109

Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: Bosch Security Systems, 130 Perinton Parkway, Fairport, NY 14450
Contact: Frank Mioduszewski (585) 678-3368 FAX (585) 678-3263

DESIGN: Models D278S, D298S, and D298M smoke detector bases. Bases may be used with Model D299 relay module (CSFM Listing No. 7300-1615:110). Refer to listee's data sheet for detailed product description and operational considerations.

RATING: D278S =9.6-13.9 VDC
D298S, D298M = 18.9-28 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rating, and UL label.

APPROVAL: Listed as smoke detector bases for use with listee's separately listed fire alarm control units and Models D285 *(CSFM Listing No. 7272-1615:134), and D603, D604, D605 *(CSFM Listing No. 7271-1615:178) detector heads. Refer to listee's Installation Instruction Manual for details.

12-17-07 mt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 28, 2008**

*Listing Expires **June 30, 2009***

Authorized By: **BEN HO, Chief**
Fire Engineering Division